

OSART Good Practices

OPERATIONS

Fire prevention and protection programme

South Ukraine3, Ukraine

Mission Date; 9-25 Oct., 2006

Organization of fire fighting.

The organization for fire fighting is above current standards in the industry. The fire brigade, with all equipment which could be vital, is on shift and always ready to operate. The premises of the fire brigade are very close to the plant. The firemen and operations staff are adequately instructed and trained. The facilities used to train firemen are numerous and adapted to the needs of a nuclear power plant.

- The fire brigade is located 500 m from the plant.
- There are 10 fire cars, well equipped and kept in very good condition.
- An officer will manage the operations in the field from a command-car.
- Alarms come directly from the field or from the main control room.
- There is a realistic smoke simulation underground where many scenarios are carried out.
- The organization can easily find the premises in a fire. They have clear and exact keeping of documentation.
- The training schedule is adequate.
- In case of a fire in the control area, the personnel have group and individual dosimeters.
- The brigade will be quickly supported by two other fire brigades, located within 5 km of the plant.

St. Laurent, France

Mission Date; 27 Nov.-14 Dec., 2006

A "Fire Committee" including representatives of various plant departments analyses and implements rules and carries out inspections in the field.

The plant has set up a Fire Committee ("Commission Incendie") composed of representatives of various departments and projects of the NPP's organization (risk prevention, operations, site protection, mechanical and electrical, dismantling of Saint Laurent A, emergency planning and preparedness, fire action plan). This committee is headed up by the senior manager in charge of safety and quality department. Its secretary and animator is the fire officer, fire safety coordinator.

This committee is in charge of analysing and implementing new regulations and EDF corporate policies and operational experience related to fire prevention and protection.

The activities of this committee are:

- to conduct multidisciplinary activities,
- determine the priority of actions to be taken,
- define an action plan with relevant people in order make it easier to take into account prescriptions related to fire protection and improve "fire culture",
- to carry out controls of activities related to prevention, training and fire fighting.

For these purposes, its members carry out systematic walk-downs in the installations at least twice a month. The deviations observed are documented and tracked.

The team considers that this committee is a powerful mean of disseminating in a practical way the fire protection concern in all departments of the NPP. Furthermore, the periodic walk-downs performed by a team of people having various backgrounds increase efficiency of these inspections.

Yonggwang, Korea, Rep. of

Mission Date; 16 Apr.-3 May, 2007

Fire-rated penetration labels and containment penetration labels are placed on the walls for easy identification of such points in the field.

Currently, thanks to more than 10,000 identification labels on fire-rated penetrations and containment penetrations, the visual inspection, leakage test and post maintenance activities are implemented more efficiently.

An identification label is attached to the wall at eye level. Arrows and serial numbers, indicating the location of the penetration, are affixed so that the relevant fire-rated or containment penetration among others is easily identified in the field.

A visual inspection of the fire-rated penetrations and leakage test of the containment penetrations is implemented every 18 months. Therefore, besides regular inspection when staff identify a deficiency of a penetration on a field tour, they can inform the responsible person of the exact deficiency location. Follow-up measures can then be taken simply by giving the serial number on the label.

The plant has developed an ambitious programme for reducing fire hazards and improving fire fighting capability. This programme is driven by plant management and has produced improvements in staff behaviour, training, fire fighting equipment and facilities:

- The plant has developed a specific fire fighting training programme on simulator.

As part of the plant's ongoing initiative to minimize the impact of an event, such as smoke release, self-ignition or an incipient fire, on plant safety, the plant has developed a specific fire fighting training programme on simulator. This training includes various stages starting with theory and ending with practical fire fighting exercises.

The plant uses a simulator at its training centre to improve staff preparation for practical exercises. This simple, mobile, flexible system provides training in proper work practices and the use of appropriate equipment in a broad range of situations simulated on a wide screen.

The simulator is managed by a specific computer programme made up of a screen displaying the situation, a touch-sensitive pad on which the trainee stands and a bank of extinguishers equipped with sensors. The simulator accurately reproduces the development or control of the fire on the basis of the trainees' actions, for instance selection and use of a type of extinguisher, distance from flames, etc.

This simulator has improved the efficiency of this training, thanks to:

- Numerous scenarios and quick development: more content in less time.
- Simulates near-real conditions without the related disadvantages: no need to create a fire and therefore no pollution, less stress for the trainees, who are more receptive to information as a result.
- Easy to implement: centralizes training resources at the plant, significantly reduces cost and effort of traveling (time wasted, fatigue, transport risks, pollution).

- The plant has published a leaflet: "Management of movable fire loads".

The leaflet provides information and tips in a handy format which is accessible to all workers, setting out the basic moveable fire load management principles, with a few chosen illustrations.

It defines the products concerned and the rules for storage outside warehouses, the use of a fire-proof cabinet and temporary storage. One section shows the "moveable fire load sheet".

This sheet is crucial in ensuring in-depth defense of equipment items and developing a questioning attitude. It details storage areas and their capacity (nature of the products and maximum quantities authorized) which have been determined according to the detection and protection capacity of the rooms, the distance from any ignition source and the absence of safety-related equipment.

This leaflet is a simple, inexpensive method which attracts people's attention and gives them additional reminders. It is sent to each member of staff individually by post and is also

available in racks located in areas where people pass through. It is also publicized on the public address terminal (PAT) television screens installed in over twenty areas on the site. It will likewise be included in the new version of the welcome package (in the same way as other information leaflets), to be given to all new employees from 1 July 2007.

The "moveable fire load sheet" is supported and promoted by a manager of the site, thus ensuring that the initiative receives customized attention.

Forsmark, Sweden


Mission Date; 12-28 Feb., 2008

Effective management of fire cells

Fire cells monitoring - Fire cells divide the unit into separate compartments in order to prevent the spread of fire and fumes. In order to monitor the integrity of the fire cells, each door in the fire cell is monitored and an alarm is tripped if a door is open too long. (Fig. 1) This feature ensures a high standard for fire cells integrity, even during outage. Anyone who is in the plant and discovers an open fire cell door must close it. If this is not possible, the Shift Supervisor must be informed immediately.

Fire cells service openings - During work, service openings are used whenever possible. When in use these are sealed by seal bags specially designed for this purpose. (Fig. 2) This feature ensures that the fire cells are closed even during work in plant.

(Fig. 1)



(Fig. 2)



Adaptive Fire Alarm Detectors - The fire alarm detectors system can be adapted (with increased or reduced sensitivity) to the actual work situation in specific plant rooms. Changes can be accomplished via a PC software application, e.g.: when hot work is performed or a transportation vehicle enters into the plant. The fire alarm detectors are always ready to monitor fire status; there is no need to switch them off completely. The sensitivity of the fire alarm monitoring system is specified by the fire protection foreman when issuing the directive for fire protection measures as part of work authorisation process.

Cruas, France

Mission Date; 24 Nov.-11 Dec., 2008

Presence of a professional fire-fighter seconded to the plant.

The plant has engaged a professional fire-fighter in order to provide assistance concerning all questions in this area and to maintain contact with the municipal fire brigades. Agreement with the local fire response centre (SDIS), aimed at strengthening the relationship, ensures that all conditions are in place to improve fire prevention and the effectiveness of fire fighting. The provision of a professional firefighter falls within the scope of this agreement.

The professional firefighter provides the plant with his expertise in prevention and prediction, training and organisation of emergency response operations. He is involved in risk assessments, training of EDF and SDIS staff and developing fire scenarios. He also participates in the improvement and consolidation of the partnership between EDF and SDIS. The ETARE plans ("listed facility plans"), which provide off-site emergency services with all relevant information about the plant facilities, were developed with his assistance.

A further benefit is the observation during exercises of operations staff by a professional firefighter with the aim of improving their approach to firefighting, their organisation and the command effectiveness of emergency response supervisors. In addition, the professional firefighter, as a first aid monitor, applies his skills at the earliest stage while awaiting the response of medical services in the event of an accident on site.

Improving the skills of members of response teams in respect of incipient fires helps control fires at the initial stage before they have consequences for nuclear safety, personnel or the plant.

Mihama 3, Japan

Mission Date; 20 Jan.-5 Feb., 2009

A surveillance camera network that operates simultaneously with the fire alarm was established in order to secure the safety of operators, etc, during the initial response in the case of a fire incident.

Surveillance cameras (approximately 230 in MIHAMA unit 3; approximately 700 in the entire site) were established near the fire alarms of the turbine building, reactor auxiliary building, reactor building, and radioactive waste building.

The surveillance cameras operate simultaneously with the fire alarm when it goes off. A sign signaling a fire and images near the fire alarm are displayed on the surveillance monitor, and the system notifies all concerned parties of the fire in the central control room and countermeasure headquarters, etc, by switching on the Patlite lights and sounding a buzzer.

As the installation of the system allows for advance verification of the field when necessary during an accident such as a fire or steam leakage through the cameras from within the central control room, it has been very useful in allowing for the equipping of optimal protective equipment and verifying the field in advance, and securing the safety of operators, etc, that conduct the initial response.

Cattenom, France

Mission Date; 14 Nov.-1 Dec., 2011

Drawings to manage fire zone deviations

The plant has developed drawings to manage fire zone deviations. These drawings show the contours of the fire zones and the elements in the fire zone (doors, bushings, check-valves, siphons...) and are used as a basis to draw plans indicating how modifications or deviations may affect fire safety.

Identification of each deviation in the fire zone are marked on a drawing of the room which enables quick and precise location of the element.

The drawings are working documents which reduces the risk of error when needing to identify a certain element in the fire zone during maintenance.

The drawings are also available to the plants Fire Team Leaders who takes them with him/her in the field in case of fire alarm. The marking of fire zoning deviations on a graphic support document increases operational efficiency of fire safety as this document is easily usable by the EDF Fire team and the off-site fire fighters.

Field operators, as well as contractors working on the walls of fire zones, receive training from the fire zoning drawings to raise the awareness and to identify deviations.

Cattenom, France

Mission Date; 14 Nov.-1 Dec., 2011

Fire load displayed on the back of a "Entreposage" temporary warning sign, based on the type of materials stored.

The plant has a system to display the fire load on the back of a temporary warning sign which enables workers in the field to calculate fire loading, based on the type and quantity of the stored materials.

The sign is displayed on materials and equipment stored in dedicated temporary storage areas. It is used to identify the owner of stored materials and to indicate fire load with related risks.

The advantage is easy and accurate calculation of total fire load of stored materials and equipment. It is easy to check whether maximum limits are complied with and to provide for easy monitoring and control of the fire loading.

Flamanville, France

Mission Date; 6-23 Oct., 2014

The station has developed emergency response plans for use by external emergency response teams.

The station has developed emergency response plans for each building for use by external emergency response teams. The plans contain the following information:

- Firefighting resources such as floor plans; locations of access; locations of fire detection & protection equipment.
- Risk assessment for each area
- Fire scenarios possible in each area
- Illustrations of large equipment

These emergency response plans facilitate easy, accurate exchange of information between the station's on-call director of the senior management command post (PCD2) and the emergency response operations commander (off-site response). The response plans speed up the deployment of external firefighting resources and helps the emergency response operations commander to define the SOEIC (Situation – Objective – Concept of operations – Execution – Command).

Paks, Hungary

Mission Date; 27 Oct.-13 Nov., 2014

The plant has recently introduced the holders for fire extinguishers seismically fixed on the floor. Several hundreds of fire extinguishers cannot always be fixed on the wall due to different reasons. In some locations inside the controlled area the possibility to get the fire extinguishers fixed to the wall is limited by stainless still liner or due to decontamination needs. In some locations extinguishers may be obstructed by equipment, decreasing visibility and access.

The new fire extinguisher holders are able to fix them in place even in case of a seismic event preventing potential damage or personal injury caused by the displaced fire-extinguisher. The phosphorescent pictorial sign on the holder, visible from three sides at head-up level, makes significantly easier location of fire-extinguisher in case of poor lighting conditions. The team has found that this is a good practice.



Management of transient combustible materials

The station has developed and implemented strong systematic management and control of combustible materials.

- (1) The primary contractor submits an application to the Maintenance Management Group. At that time, the field map (indicating 'no temporary storage' areas, hot work areas and other temporary storage areas) is verified on the intranet to select a storage location. At the same time, fire load assessment of the temporary storage item is conducted.
- (2) The Maintenance Management Group checks the application and verifies 'period,' 'reason', 'location', 'important equipment: Yes/No', 'if Yes, adequacy', 'items (include quantity, calorific value)', 'TEPCO group in charge', 'primary contractor', 'fire load assessment results'. The result of the fire load assessment is compiled by the Maintenance Management Group, and it verifies in advance if there are any temporarily stored items in the same area. If there are already items being stored temporarily, the total calorific value, obtained by adding together the assessment results, is used to determine if temporary storage can be permitted. A 'Request for correction' is issued if necessary. Applications with no issues are sent to the TEPCO work supervisor.
- (3) The TEPCO work supervisor circulates the application to the manager(s) for verification. Once it is approved (permitted) by the shift supervisor, the application is returned to the primary contractor.
- (4) The approved application is shared as information with the Maintenance Management Group, and the field map is updated.
- (5) The application returned to the primary contractor is posted in the field, and items are temporarily stored.
- (6) The TEPCO work supervisor and primary contractor manager checks the status of temporary storage in the field and puts the date and signature of the verifier on the posted application form.
- (7) The Maintenance Management Group conducts daily patrols based on the information registered on the field map and verifies temporary storage conditions from an independent perspective. A 'Request for correction' is issued if necessary.

Note that in-field equipment and materials for operations shifts are also managed as part of the scope of these rules.

Exemptions

If temporary storage is unavoidable in a 'no temporary storage' area due to maintenance activities, an exemption application is submitted in advance to the fire protection management for approval. The approved exemption application and temporary storage application are submitted together to the Maintenance Management Group.

For exemptions, additional safety measures (such as placement of temporary fire detectors and ensuring use of metal containers) are considered and implemented.

Limited authorization time of hot work permits

Hot work permits in OL1 and 2 are authorized for one shift (up to 12 hours) only.

The shift and fire brigade are assigned to control and supervise hot work in the plant.

In terms of fire prevention, hot work is managed effectively by following a strict limit on the validity of hot work authorizations. A hot work permit is only valid at most for 12 hours at a time. The fire brigade always visits the hot work site before the start of the work, and the hot work permit is kept at the work site for the duration of the work. When the work is completed the fire brigade visits the work site to inspect the situation and takes away the hot work permit from the work site. The fire brigade keeps up-to-date information on the plant's ongoing hot work on the bulletin board.

This process creates a sense of ownership with staff and ensures a systematic control of combustible material and ignition sources.

This practice minimizes fire risks created by hot work in the units.

Additionally this guarantees that the fire brigade always has up-to-date information on the ongoing hot work at the plant. There have been no fire events applicable to hot work for many years at the plant.

Bugey, France

Mission Date; 2 -19 Oct., 2017



SECUREVI emergency response information system

SECUREVI is a software programme for use in an on-site emergency that maps the site in detail, with clickable icons for each building that allow users to display operational information about the building, as well as 360-degree images of the building interior and exterior.

The software - installed on a portable computer on board the on-site emergency command vehicle - also allows graphic information about the real-time tactical situation (details of hazards such as smoke/flames, current risks, response teams/equipment deployed, and planned actions) to be overlaid on interior and exterior building images.

SECUREVI supports emergency teams to respond to a crisis in real time. It can also be used for training purposes, and to collect operating experience after an event (the software records details of an emergency event on a minute-by-minute basis).

Initially developed for the public emergency services, SECUREVI has been designed to meet the operational needs of the station. Bugey is a pilot site for the implementation of the software.








Figure 2: Detailed view of the Fire Station Systems Status in Maintenance Workshop Area