



[Click here to start](#)



MOBILE HOT CELL FOR THE CONDITIONING OF HIGH ACTIVITY SOURCES


**Linde Nel
Necsa, South Africa**

Background

- Proper management of spent sealed radioactive sources a priority
 - Developing countries: Poor accounting systems and/or lack of expertise/funds
- Spent High Activity Radioactive Sources (SHARS) especially problematic
- No standard procedures or suitable technologies
- In 2003 – concept of a mobile hot cell evaluated by international team of experts



Project Development




Application of Unit

- Transport unit into country – assemble and prepare for operation
- Removal of SHARS from working shields and transfer into long term storage shield
 - Removal of head/irradiator from working device
 - Partial dismantling of head/irradiator outside cell
 - Placement inside cell and further dismantling
 - Removal of SHARS
 - Encapsulate in stainless steel capsule – welding and leak testing
 - Placement into LTSS
 - Stored safely and securely
- Dismantle unit and transfer to next country

Design of Unit

View from the top



Cell walls – Double cavity wall
1,55 m thick - filled with river
sand with density of 1,6 - Mild
steel “shuttering” plates
Working volume 1,6 m x 2,5 m x
3 m high


Design of Unit

View from the Side

Roof – 3 x 0,23 m thick concrete slabs
Window – oval shaped steel container
with polycarbonate ends - filled with
50% ZnBr₂
Telescopic manipulators with 20 kg
lifting capacity

Auxiliary Equipment

Jib crane on inside
Exhaust ventilation unit
360° camera coverage on inside
Table with tools, welding and leak testing
equipment
Lighting
A-frame crane over unit















Demonstration of Unit


- March 2007 – pilot operation performed at Necsa
- 2133 Ci Co-60 source conditioned
- Witnessed by peer review team – USA (Los Alamos and NRC), UK, Belgium, Sudan and South Africa)
- Exposures well within modeled and calculated values – maximum 109 μSv
- Conclusion
 - SHARS Installation qualified
 - SHARS teams qualified

Advantages

- Safety proven
- Allows for easy transportation
- Inexpensive
- Easy to operate
- Easy to assemble

Long Term Storage Shield

- Designed by RWE Nukem (UK)
- 4 Drawers with 10kCi capacity



Special Form Material



Department of Health

Directorate: Radiation Control
Private Bag 952
BELLVILLE
7530

Tel: 021-9466182
Fax: 021-9461689
E-mail: rcv@health.gov.za



Web: <http://www.doh.gov.za/department/radiation/>

CERTIFICATE NUMBER ZA/NLM52/S-2008

SOUTH AFRICAN COMPETENT AUTHORITY CERTIFICATE OF APPROVAL FOR SPECIAL FORM RADIOACTIVE MATERIAL

The Department of Health: Directorate Control, being for the purpose of the Regulations of International Atomic Energy Agency, the Competent Authority in the Republic of South Africa in respect of the transport of radioactive material, certifies herewith that the NLM52 capsule design, described herein, meets the requirements for special form radioactive material as defined in the document IAEA Safety Series TS-R-1, Regulations for Safe Transport of Radioactive Material, 2006 Edition.

1. Identification

ZA/NLM52/S-2008

2. Form Description of Special Form Radioactive Material

The NLM52 capsule family is designed for the encapsulation of sealed sources, which will be obtained during the conditioning of spend sources (SHARS). The material used is 316 L stainless steel. The maximum capsule outer diameter is 52.0 mm. The overall capsule lengths are 76, 152, 202, and 327 mm respectively. Each capsule is identified by length as follows:

NLM52-74
NLM52-150
NLM52-200
NLM52-250
NLM52-325

All capsules have the same lid, which is welded into a recess at the cylinder end. The exact configuration is detailed in drawings J5182-00-00 Rev R3, J5182-00-01 Rev R3 and J5182-00-05 Rev R3.

3. Radioactive Contents

The following nuclides and maximum activities are allowed:

Co-60 (185 TBq)
Cs-137 (740 TBq)
Ra-226 (370 GBq)

Am-241 – each capsule's activity limit is as follows:

NLM52-74 (3.8 GBq)
NLM52-150 (6.7 GBq)
NLM52-200 (11.9 GBq)
NLM52-250 (15.1 GBq)
NLM-52-325 (20.0 GBq)

Mixtures of nuclides are not permitted.

This certificate does not relieve the consignor from compliance with any requirements of the Government or any other Government of any country through or into which the package may be transported.

CERTIFICATE NUMBER ZA/NLM52/S-2008

4. Quality Assurance Program

The design, development and qualification of the NLM52 family of capsules were performed by the Nuclear Liabilities Management (NLM) department of Necsca. The design, manufacture, development and qualification activities were performed in accordance with the NLM implemented quality management system which complies with the requirements of ISO 9001:2000.

5. This certificate is issued in response to an application by Nuclear Services – a Division of Necsca, letter PDO-LET-08/002 dated 29 April 2008.

6. This certificate expires at midnight on 30 June 2012

Signed at Bellville on 20 June 2007


DIRECTOR GENERAL- HEALTH

This certificate does not relieve the consignor from compliance with any requirements of the Government or any other Government of any country through or into which the package may be transported.

Impact test



Percussion test



Heat test




Leak test

- Weld qualified during Special Form certification.
- Field confirmation test by Vacuum bubble test according to ISO 9978:1992(E): International standard: “Radiation Protection – Sealed radioactive sources – leakage test methods” par 6.2.1



QA

- Data sheet completed per capsule
- Evidence of all processing steps
- After bottom lid weld, capsule helium leak tested
- Record of contents
- More detail of sources on other forms

NLM52 Special Form Capsule welding log				
Capsule info	Capsule no			
	Cylinder no	Lid 1 no	Lid 2 no	
	Verified compliance (review inspection report)			
	Name	Date	Signature	
This sheet is based on PDO-OP-002 Rev 0				
Bottom lid weld	Action		Paraf	Date
	1	Perform 'Motor Calibration' (attach print-out)		
	2	Perform 'Test Weld' (attach print-out)		
	3	Gas pressure at least 200kPa and flow 15L/min		
	4	Lid pressed correctly in position		
	5	Attach the applicable weld head capsule holder for cylinder length		
	6	Insert capsule		
	7	Position weld needle using spacer		
	8	Fill capsule with argon and return quickly in weld head		
	9	Position weld head and execute weld (attach print-out)		
Compliance	10	Visual inspect weld		
	11	Perform helium leak test on weld (attach report)		
	12	Seal welded capsule in plastic		
Weld not leaking and visual sound				
	Name	Date	Signature	
Content	13	Record content:		
Top lid weld	14	Attach the applicable weld head capsule holder for cylinder length		
	15	Perform 'Motor Calibration' (attach print-out)		
	16	Perform 'Test Weld' (attach print-out)		
	17	Gas pressure at least 200kPa and flow 15L/min		
	18	Place open filled capsule in weld head, position welding needle using spacer		
	19	Remove capsule from head		
	20	Fill open capsule with argon and place lid in position		
	21	Press lid correctly in position		
	22	Insert capsule in weld head		
	23	Position weld head and execute weld (attach print-out)		
Compliance	24	Visual inspect weld		
	25	Bubble test		
	Performed as prescribed, weld visual sound and no leaks detected			
	Name	Date	Signature	

The Way Forward

- Further developments
 - Licensing – LTSS as transport container
 - Security – Improve the Design of LTSS
- Integration of the Borehole disposal concept and SHARS conditioning facility

Summary

- SHARS installation successfully demonstrated - safe.
- Safety and security ensured
- Mission completed – Sudan, Tanzania and Uruguay
- Pre-mission – Philippines and Brazil